

## **Corrigendum-3**

**Dated: 02.06.2016**

**Tender no: RailTel/Tender/OT/SR/DC/2015-16/124**

### **Existing Clause 3.9, Section– I, chapter – II**

The successful contractor shall obtain Tier III site certification from UPTIME Institute for 612KW load. The bidder is solely responsible for the design. The design provided by RailTel as part of this RFP is the minimum requirements. The bidder may make suitable modifications, if required, to meet the Tier III guidelines and submit the design along with the bid”.

### **Clause 3.9, Section– I, chapter – II should be read as;**

#### **3.9 Tier III Certification**

**3.9.1** The successful contractor shall obtain Tier III site certification from UPTIME Institute for 612KW load. The bidder is solely responsible for the design. The design provided by RailTel as part of this RFP is the minimum requirements. The bidder may make suitable modifications, if required, to meet the Tier III guidelines and submit the design along with the bid.

**3.9.2** If the bidder’s design/solution document for Phase-II proposes alterations in the Phase-I which alters/affects/modifies the already UPTIME Tier-III Design certification of Phase-I & II, fresh certification for Design of Phase-I & II shall be obtained by the bidder, bearing the total cost of certification. RailTel will not pay any additional charges towards this fresh Design certification of Phase-I & II.

**3.9.3** In the event of changes in design as mentioned in para 3.9.2 above, if the constructed facility of Phase-I which is already Tier-III certified needs alterations/modifications and consequent re-certification by UPTIME for Tier-III Constructed facility, the bidder has to bear the total cost of such fresh Tier-III Facility Certification by UPTIME for Phase-I. RailTel will not pay any additional charges towards such fresh Facility certification of Phase-I.

**3.9.4** In the event of alterations/modifications and consequent fresh certification process for constructed facility of Phase-I as mentioned in para 3.9.3 above, interruption free service to Phase-I customers shall be ensured by the bidder, deploying required resources and expertise at site. RailTel will not pay any additional charges towards the same.

**There is no change in the Last Date of submission and opening of tender**

**sd-**

**(S.Rajasekhar)  
Addl.GM/Projects/SR  
for RGM/SR**